STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155221	A. BUILDING 01 B. WING _____	R 10/02/2012

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
DAVIS GARDENS HEALTH CENTER	1120 E DAVIS DR TERRE HAUTE, IN 47802

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification, State Licensure and Quality Assurance Walk-thru Survey conducted on 07/25/12 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 10/02/12 Facility Number: 000126 Provider Number: 155221 AIM Number: 100266400 Surveyor: Bridget Brown, Life Safety Code Specialist At this PSR survey, Davis Gardens Health Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This two story facility was determined to be of Type II (222) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detection in the corridors and spaces open to the corridors. Battery powered smoke detectors were provided in all resident rooms. The facility has the capacity for 78 and had a census of 69 at the time of this survey. The facility was found in compliance with state law in regard to smoke detector coverage and	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155221	A. BUILDING 01 B. WING _____	R 10/02/2012

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
DAVIS GARDENS HEALTH CENTER	1120 E DAVIS DR TERRE HAUTE, IN 47802

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 sprinkler coverage. All areas where the residents have customary access were sprinklered and all areas providing facility services were sprinklered. Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 10/05/12.	{K 000}		